

सीएसआईआर-केन्द्रीय खनन एवं ईंधन अनुसंधान संस्थान

(वैज्ञानिक तथा औद्योगिक अनुसंधान परिषद्)

बरवा रोड , धनबाद - 826015 , झारखण्ड, भारत



CSIR-Central Institute of Mining & Fuel Research

(Council of Scientific & Industrial Research)

Barwa Road, Dhanbad - 826015 , Jharkhand , India

ORIGINAL COPY



**SPEED POST/COURIER SERVICE**

No. CIMFR/TC/P/11655

Dated: 17 February 2012

Equipment ID NO. 72/12

Code No. FLP/242/11-12

To,

**M/S. KAYSONS TECHNO EQUIPMENT PVT. LTD.,**

1802/7, PHASE- IV, G.I.D.C ESTATE,

VITHAL UDOGNAGAR - 388 121

**GUJARAT (INDIA)**

**Sub:** Flameproof Testing as per IS/IEC 60079-1: 2007 and weatherproof testing as per IS/IEC 60529:2001 IP-66 of your **FLP & WP Flood Light Fitting**, rated 500W GLS, 400W/250W HPMV, 250W MLL, 85W CFL, 100W LED & 400W MH at 240V AC in cast aluminium Alloy LM-6 construction designated by **Type No.: KFL-A** for use in Zone 1 & 2 and Gas Group: IIB atmosphere only.

**- Report on (Prototype)**

**Your Ref. Appl. No.: KTPL/CIMFR/KFL-A/11-12**

**Dated: 01/01/2012**

Dear Sir,

Please find enclosed the **Test Report (Prototype)** of the above sample submitted by you.

Charges of

including applicable service charges involved towards the testing /issuing the schedule have been adjusted against the advance deposit made by you.

Kindly arrange to collect the sample within 90 days from the date of receipt of this letter failing which CIMFR would dispose off the sample by public auction without any further NOTICE to you.

Kindly acknowledge receipt.

Thanking you.

Yours faithfully,

(G. M. PRASAD)

HEAD OF THE DEPARTMENT  
**TESTING CELL**

Encl: As above.

Prototype Test Report in **Four Copies**

Copy to: 1. Head, Flame & Explosion Lab.

2. Bill Section.

EPABX : 0091-326-229-6027/6028/6029

Fax : 0091-326-229-6025 , email : dcmrips@yahoo.co.in

Working Days : Monday to Friday, Website : www.cimfr.nic.in



ORIGINAL COPY

**CENTRAL INSTITUTE OF MINING AND FUEL RESEARCH**

FORMERLY : CENTRAL MINING RESEARCH INSTITUTE

(COUNCIL OF SCIENTIFIC & INDUSTRIAL RESEARCH)

बरवा रोड, धनबाद-826015 (भारत)

BARWA ROAD, DHANBAD-826015 (INDIA)

**परीक्षण प्रमाण पत्र - TEST CERTIFICATE**

FORMAT NO.: (CIMFR: DQM: FLP02: F-01:REV-01)

(Flame & Explosion Laboratory)

|  |                          |
|--|--------------------------|
| Proto Report No.: CIMFR/TC/PIH655            | Dated: 17 February, 2012 |
| Equipment ID NO.: 72/11                      | Code No.: FLP/242/11-12  |
| Application Ref. No.: KTPL/CIMFR/KFL-A/11-12 | Dated: 01/01/2012        |

1. Applicant : M/S. KAYSONS TECHNO EQUIPMENT PVT. LTD.,  
1802/7, PHASE- IV, G.I.D.C ESTATE,  
VITHAL UDOGNAGAR - 388 121  
**GUJARAT (INDIA)**
2. Manufacturer : Same as above
3. Apparatus : FLP & WP Flood Light Fitting.
4. Designated by : Type - KFL-A
5. Gas Group, Zone : Gas Group : IIB and Zone 1 & Zone 2 atmospher only.
6. Electrical ratings: rated 500W GLS, 400W/250W HPMV, 250W MLL, 85W CFL, 100W LED & 400W MH at 240V AC
7. Temperature Class: (See result # A2)
8. Degree of Ingress Protection: IP-66, (see result # A4)
9. Material of Construction: Cast aluminium Alloy LM-6. Refer drawing for material thickness at different locations of the enclosure.

**10. Description of the apparatus FLP & WP Flood Light Fitting.**

**A.**


| Description              | Volume (in cc) |         | Min. Wall thickness | Nos. & Size of Bolts/Fasteners       |
|--------------------------|----------------|---------|---------------------|--------------------------------------|
|                          | Gross Volume   |         |                     |                                      |
| Name: Main Enclosure     | 14000 cc       | 8000 cc | 6mm                 | Grub screw.                          |
| Name: Terminal Enclosure | 200 cc         | 150 cc  | 4mm                 | 2 nos. M6 x 20 long Allen cap screw. |

Note: For further details refer drawings.

*Arvind Kumar*



सीएसआईआर - केम्पस परीक्षण प्रकोष्ठ  
CSIR - CIMFR TESTING CELL



ORIGINAL COPY



TEST CERTIFICATE प्रमाण पत्र

FORMAT NO. IMFR-DOMESTIC-PO2: F-01:REV-01  
(Flame Proofing Laboratory)

ID NO.: 72/11

Code No.: FLP/242/11-1211

B.

| Glass details   | Max no. of aperture on cover |
|---|------------------------------|
| Size = $\varnothing$ 310mm opening, Shape = Round<br>Type = Toughened Type 'A'<br>Thickness = 18mm<br>Cemented Path = 34mm<br>Sealing Material = Litharge + Glycerin with calcium sulphate.<br>COT : - 20° to 220°C | NIL                          |

**Nature of Flameproof Joint:** Type of joints and gaps (Threaded, Spigot joint for Gas Gr. IIB)

| Sr. No | Location of flamepath                    | Type of joint  | Min. length of flamepath/Axial threaded length (in mm) |       | Max. gap/no. of threads (in mm) |               |
|--------|--|----------------|--|-------|---------------------------------|---------------|
|        |  |                | Req.   | Spec. | Req.                            | Spec.         |
| 01.    | Between Main Enclosure and Glass cover.  | Threaded Joint | 8  | 19    | 5                               | 9 (pitch 2mm) |
| 02.    | Between Main Enclosure and Spacer.       | Threaded Joint | 8  | 10    | 5                               | 6 (pitch 1.5) |
| 03.    | Between Spacer and Terminal plate        | Threaded Joint | 8  | 10    | 5                               | 6 (pitch 1.5) |
| 04.    | Between Terminal plate and Terminal Box. | Spigot Joint   | 12.5   | 12.5  | 0.15                            | 0.15          |

**Terminal Studs:** 2 nos. DMC moulded terminal studs are provided in the terminal plate maintaining flamepath 25mm and diametrical clearance 0.2mm. Check nuts are provided for locking arrangement.

**Max. No. & size of cable entries:** One no. M25x1.5P Cable entry provided on the Terminal box maintaining 13mm threaded path with 8 nos. full thread engaged for attachment of appropriate and approved & certified double compression type cable glands.

**12. Name plate and warning inscription:** The name-cum-warning inscription plate and rating plate made of Brass/SS is permanently fixed on the cover of enclosure by hammer driven rivets leaving min. 3mm material thickness below the rivets. The warning inscription shall read as "DO NOT OPEN WHILE ENERGIZED".


**13. Drawing:** The unit is designed and constructed as flameproof and weatherproof in accordance with the following drawing conforming to the requirements of IS/IEC 60079-0: 2004 and IS/IEC 60079-1: 2007.

| Sl. No. | Drg. No. | Title   | Rev. | Sheet  | Date       |
|---------|----------|---|------|--------|------------|
| 1.      | FL001-10 | FLP & WP FLOOD LIGHT FITTING.<br>TYPE - KFL-A | 0    | 1 OF 1 | 01/01/2012 |



सीएसआईआर केम्पेईसं परीक्षण प्रकोष्ठ

CSIR-CIMFR TESTING CELL



ORIGINAL COPY



TEST CERTIFICATE / परीक्षण प्रमाण पत्र

FORMAT NO.: CIMFR/COM/FLP02: F-01:REV-01  
(Flame & Explosion Laboratory)

ID NO.: 72/11

Code No.: FLP/242/11-1211

**14. Any other relevant information:**

- 1) As per Clause 4.2.1 Note - 2 of IS/IEC 60079-0:2004 the apparatus mark IIB is suitable for application requiring IIA apparatus.
- 2) The material of construction of the FLP/WP Flood Light Fitting may be C.I. grade FG 200/ Brass / Steel instead of cast Aluminum alloy LM6 construction.
- 3) The above FLP/WP Flood Light Fitting may be used as a FLP/WP high bay light fitting.

**15. Declaration by the Applicant/Manufacturer:**

(i) As to standards with which the apparatus complies in respect of:

- a) Electrical apparatus for Potentially Explosive atmosphere - General requirements: IS/IEC 60079-0: 2004
- b) As to flameproof protection IS/IEC 60079-1: 2007
- c) Ingress protection as per IS/IEC 60529: 2001

(ii) **Composition of the cast aluminum alloy LM-6 declared by the manufacturer:** Composition of cast aluminum alloy LM-6 purported to be forming the material of construction of the enclosure has been declared by the manufacturer in the Drg. no. FL001-10, sheet no. 1, rev-0 Dated: 01/01/2012.

**COMPOSITION OF ALUMINIUM ALLOY LM-6**

|          |               |           |                   |
|----------|---------------|-----------|-------------------|
| Copper   | 0.1 % (max.)  | Silicon   | 10 to 13 % (max.) |
| Titanium | 0.2 % (max.)  | Lead      | 0.1 % (max.)      |
| Tin      | 0.06 % (max.) | Magnesium | 0.1 % (max.)      |
| Iron     | 0.6 % (max.)  | Zinc      | 0.1 % (max.)      |
| Nickel   | 0.1 % (max.)  | Manganese | 0.5 % (max.)      |

Aluminium by difference 85 to 88%

However no sample of the alloy was drawn from the prototype enclosure for verifying its chemical composition declared by the manufacturer

**16. Documents/Samples Submitted :**

- i) Application form
- ii) Drawings
- iii) Prototype sample

**17. Compliance of prototype or sample with documents:** The test sample of electrical apparatus submitted for the type tests complies with the manufacturers documents referred above.

**Note:** CIMFR has however not checked and tested the compliance of the apparatus to any standard other than the above standards.

**SCOPE OF THE TEST CERTIFICATE**

The Test Certificate issued by CIMFR testifies that the apparatus has been found to comply with the definition of flameproof-weatherproof APPARATUS contained in the relevant Standard specifications. They do not vouch for the quality of the equipment in any other respect.

**This Institute reserves the right to review amend or withdraw this Test Report at any time if considered necessary in the interest of safety.**



सीएसआईआर - केवईएस परीक्षण प्रकोष्ठ

CSIR - CIMFR TESTING CELL

TESTING CELL  
ESTD. 1956

ORIGINAL COPY



TEST CELL CERTIFICATE परीक्षण प्रमाण पत्र

FORMAT NO.: (CIMFR: DQM: FLP02: F-01: REV-01)  
(Flame & Explosion Laboratory)

**Proto Report No. CIMFR/TC/P/11655**      **Dated: 17 February, 2012**

**ID NO.: 72/11**      **Code No.: FLP/242/11-1211**

**REPORT OF TEST****Date of Test: 02/02/2012****Test Equipment Used:**

- Computer, Kistler Piezo Electric Transducer and Charge Amplifier for conducting Explosion Pressure Tests.
- Impact test setup
- Weatherproof test setup
- Thermal Shock test setup
- Temperature class test setup
- Hydraulic Test Setup


**Result #A: Tests as per IS/IEC 60079-0: 2004:**

| Type Tests |  |  |  |
|------------|--|--|--|
| Clause     | Tests  | Remarks  | Results<br>(Complies,<br>P- Pass, NA-Not<br>Applicable,<br>F-Fail)<br>References |
| 1          | Scope  |  | Complies   |
| 2          | Normative references   |  | Complies   |
| 3          | Terms and definitions  |  | Complies   |
| 4          | Apparatus grouping and temperature classification            | IIB  | Complies<br>(Result#A2)  |
| 5          | Temperatures   | -20 to 40° Ambient   | Complies   |
| 6          | Requirements for all electrical apparatus                    |  | Complies   |
| 7          | Non-metallic enclosures and non-metallic parts of enclosures | Tested DMC moulded terminal studs as declared by manufacturer      | Complies   |
| 8          | Enclosures containing light metals                           | For Gr. II, Mg 0.1%<br>For Zone 1 & 2                              | Complies   |
| 9          | Fasteners  |  | Complies   |
| 10         | Interlocking devices   | Grub Screw   | Complies   |
| 11         | Bushings   |  | Complies   |
| 12         | Materials used for cementing                                 | Litharge + Glycerine with calcium sulphate.<br>COT: - 20° to 220°C | Complies   |
| 13         | Ex components  | -----  | NA   |
| 14         | Connection facilities and terminal compartments              |  | Complies   |

*T. N. Chatterjee*



सीएसआईआर - केन्द्रीय परीक्षण प्रकोष्ठ  
CSIR: CENTRAL INSTRUMENT TESTING CELL



ORIGINAL COPY



## TEST CERTIFICATE / परीक्षण प्रमाण पत्र

FORMAT NO.: FLP/242/11-1211 (FLP02: F-01:REV-01)  
(Flame & Explosion Laboratory)

ID NO.: 72/11

Code No.: FLP/242/11-1211


|               |   |  |                            |
|---------------|---|--|----------------------------|
| 15            | Connection facilities for earthing or bonding conductors    |  | <b>Complies</b>            |
| 16            | Entries into enclosures                                     |  | <b>Complies</b>            |
| 17            | Supplementary requirements for rotating electrical machines |  | <b>NA</b>                  |
| 18            | Supplementary requirements for switchgear                   |  | <b>NA</b>                  |
| 19            | Supplementary requirements for fuses                        |  | <b>NA</b>                  |
| 20            | Supplementary requirements for plugs and sockets            |  | <b>NA</b>                  |
| 21            | Supplementary requirements for luminaries                   |  | <b>Complies</b>            |
| 22            | Supplementary requirements for caplights and handlights     |  | <b>NA</b>                  |
| 23            | Apparatus incorporating cells and batteries                 |  | <b>NA</b>                  |
| 24            | Documentation   |  | <b>Complies</b>            |
| 25            | Compliance of prototype or sample with documents            |  | <b>Complies</b>            |
| 26            | Type tests  |  | <b>Complies</b>            |
| 26.3          | <b>Tests in explosive mixtures</b>                          |  |                            |
| 26.3          | Tests for Flameproof (Ex 'd') protection                    | Verification for Compliance to Ex 'd' requirements as per IS/IEC 60079-1: 2007 | <b>P/As per Result #B</b>  |
| 26.4          | <b>Test of enclosures</b>                                   |  |                            |
| 26.4.2        | Test for resistance to Impact                               |  | <b>P/As per Result #A1</b> |
| 26.4.3/26.4.4 | Drop test   | (not a handheld apparatus or portable device)                                  | <b>NA</b>                  |
| 26.4.5        | <b>Tests for the Degree of protection IP</b>                |  |                            |
| 26.4.5        | IP of apparatus   | Ability to prevent ingress of dust & water - IP-66 as per IS/IEC 60529:2001    | <b>P/As per result#A4</b>  |
| 26.5          | <b>Thermal tests</b>  |  |                            |
| 26.5.1        | Temperature measurement                                     |  | <b>P/As per Result #A2</b> |
| 26.5.2        | Thermal shock test - for glass parts                        |  | <b>P/As per Result #A3</b> |
| 26.6          | <b>Torque Test for bushings</b>                             |  |                            |
| 26.6          | Torque test for bushings                                    | As declared by manufacturer  | <b>Complies</b>            |

*Handwritten signature*



सीएसआईआर के आईआर प्रयोगशाला परीक्षण प्रकोष्ठ

CSIR - CIMFR TESTING CELL



TEST CERTIFICATE / परीक्षण प्रमाण पत्र

 FORMAT NO.: FLP02: F-01:REV-01  
 (Flame & Explosion Laboratory)

ID NO.: 72/11


Code No.: FLP/242/11-1211

| 26.7  |  | <b>Tests for non- metallic enclosures or of non-metallic parts of encl.</b>  |  |
|-------|--|--|--|
| 26.8  | Thermal endurance to heat  | Thermal requirements declared by manufacturer for DMC moulded terminal studs<br>COT: - 20°C to 220°C   | <b>Complies</b>                                    |
| 26.9  | Thermal endurance to cold  |  |  |
| 26.10 | Resistance to light  | -----  | <b>NA</b>  |
| 26.11 | Resistance to chemical agents for Gr.I                                   | -----  | <b>NA</b><br>(only applicable for Gr. I apparatus) |
| 26.12 | Earth continuity test via non-metallic enclosure                         |  | <b>NA</b>  |
| 26.13 | Surface resistance test of parts of enclosures of Non metallic materials | -----  | <b>NA</b>  |
| 26.14 | Charging test  |  | <b>NA</b>  |
| 26.15 | Measurement of Capacitance   |  | <b>NA</b>  |
| 27    | <b>Routine verification and tests</b>                                    | <b>Manufacturer's responsibility:</b><br>Compliance to prototype of the product and physical measurement of gap and flamepath and hydraulic test at the pressure given in <b>Result#B2</b> for every sample. |  |
| 28    | Manufacturer's responsibility  | Conformity of the apparatus to the applicable standards  | <b>Complies</b>                                    |
| 29    | Marking  |  | <b>Ex d IP-66 IIB</b>                              |
| 30    | Instructions   | Instruction related to use, installation, maintenance, adjustment to be provided by the manufacturer along with the apparatus  |  |

7/8/2019

## सीएसआईआर - केन्द्रीय परीक्षण प्रकोष्ठ

## CSIR - CEMER TESTING CELL



ORIGINAL COPY



TEST CERTIFICATE 1958 प्रमाण पत्र

FORMAT NO. CSIR/IMFR/DO/02: F-01:REV-01)

(Flame Propagation Laboratory)

ID NO.: 72/11

Code No.: FLP/242/11-1211

**Result#A1:** 1kg mass of hardened steel fallen vertically on the surface of the cast aluminium alloy LM-6 enclosure and 18mm thick toughened type 'A' round in glass cover to create impact energy for group II apparatus.

**Result#A2:** The surface temperature rise classification of the Flood Light Fitting was observed after achieving the equilibrium state with following lamps energized at 110% of 240V AC Supply.

| Sl No. | Lamps with rating | Temperature Class at 40° C ambient |
|--------|-------------------|------------------------------------|
| 1.     | 500 W G.L.S       | T3                                 |
| 2.     | 400 W HPMV        | T4                                 |
| 3.     | 250 W HPMV        | T5                                 |
| 4.     | 250 W MLL         | T4                                 |
| 5.     | 85 W CFL          | T6                                 |
| 6.     | 100 W LED         | T5                                 |
| 7.     | 400 W MHL         | T3                                 |

**Result#A3:** The 18mm thick resistant toughened type 'A' round in glass cover was subjected to thermal shock test at maximum service temperature.

**Result#A4: IP-Protection:** Neoprene 'O' ring rubber gasket (3mm thick) are provide at end of each joint for weatherproof protection. Tests have been conducted as per IS/IEC-60529-2001 as tabulated below for IP-66 degree of protection.

| Sl. No | Type Tests                    |                   | Results  |
|--------|-------------------------------|-------------------|--|
| 1.     | Dust Test (First Numeral 6)   | Clause 13.4& 13.6 | No dust had accumulated inside the enclosure. <b>Pass</b>  |
| 2.     | Water Test (Second Numeral 6) | Clause 14.2.6     | No water had accumulated inside the enclosure. <b>Pass</b> |

**Cable entry temperature:** Max. 40°C ('X' mark shall appear on apparatus if temp. is more than 70°C).

*Approval*





सीएसआईआर - केन्द्रीय अखिल भारतीय परीक्षण प्रकोष्ठ

CSIR - CIMFR TESTING CELL



ORIGINAL COPY



TEST CELL प्रमाण पत्र

FORMAT NO.: FLP02: F-01:REV-01  
(Flame & Explosion Laboratory)

ID NO.: 72/11

Code No.: FLP/242/11-1211


Result #B: Tests in explosive mixtures: Tests for type of protection Ex 'd' as per IS/IEC 60079-1:2007.

| Type Tests  |  |  |   |
|-------------|--|--|---|
| Clause No.  | Description and relevant tests   | Remarks  | Results<br>(Complies,<br>P- Pass,<br>NA-Not Applicable, F-<br>Fail)<br>References |
| 1           | Scope  |  | Complies  |
| 2           | Normative references   |  | Complies  |
| 3           | Terms and definitions  |  | Complies  |
| 4           | Equipment grouping and temperature classification                                | Gr. IIB  | Complies<br>(Result#A2)   |
| 5           | Flameproof joints  | Threaded joint &<br>Spigot joint                                     | Complies  |
| 6           | Cemented joints  |  | Complies  |
| 7           | Operating rods   |  | NA  |
| 8           | Supplementary requirements for shaft and bearings                                |  | NA  |
| 9           | Light transmitting parts other than glass  | -----  | NA  |
| 10          | Breathing and draining devices which form part of a flameproof enclosure         |  | NA  |
| 11          | Fasteners, associated holes and blanking elements                                |  | Complies  |
| 12          | Materials and mechanical strength of enclosures- materials inside the enclosures |  | Complies  |
| 13          | Entries for flameproof enclosures  |  | Complies  |
| 14          | Verification and tests   |  | Complies  |
| <b>15.1</b> | <b>Tests of ability of the enclosure to withstand pressure</b>                   |  |   |
| 15.1.2      | Determination of Explosion pressure (Reference Pressure)                         |  | P/As per Result #B1   |
| 15.1.3      | Over Pressure Test   |  | P/As per Result #B2   |
| <b>15.2</b> | <b>Test for non-transmission of Internal ignition</b>                            |  |   |
| 15.2.1.1    | Test for non-transmission of an Internal ignition                                |  | P/As per Result #B4   |
| 15.3        | Reserved for future use  |  | NA  |
| 15.4        | Flame proof enclosures with breathing & draining devices                         |  | NA  |
| 16          | Routine tests  | To be conducted by the manufacturer as per Result #B2                |   |
| 17          | Switchgear for Group I   |  | NA  |
| 18          | Lamp holders and lamp caps   |  | NA  |
| <b>19.3</b> | <b>Supplementary requirements for type tests</b>                                 |  |   |
| 19.3.1.3    | Flame erosion test   |  | P/As per Result #B3   |
| 19.3.2      | Flammability   | As declared by manufacturer test has been done by third party.       | Complies  |
| 20          | Marking  | The warning inscription shall read as "DO NOT OPEN WHILE ENERGIZED". |   |



सीएसआईआर केसईअल परीक्षण प्रकोष्ठ

CSIR - CIMFR TESTING CELL



ORIGINAL COPY



TEST CERTIFICATE / परीक्षण प्रमाण पत्र

 FORMAT NO.: (CIMFR: DQM: FLP02: F-01:REV-01)  
 (Flame & Explosion Laboratory)

ID NO.: 72/11

Code No.: FLP/242/11-1211

**Result # B1: Determination of Explosion pressure (Reference Pressure Test) \*:**

Gas mixture: Test with 8% Ethylene in air .

No. of tests: 3 nos. test with each enclosure.

Test Condition: Enclosure fitted with component. and clause 15.1.2.1

| Type of Test                          |          | Gas Group      | Gas Mixture % in Air |                                      | No. of Tests            |
|---------------------------------------|----------|----------------|----------------------|--------------------------------------|-------------------------|
| Preliminary Test (reference pressure) |          | IIB            | 8% Ethylene in air   |                                      | Three                   |
| Test Ref. No.                         | Ignition | Gauge Position | Max. Pressure in Bar | Time of Pressure rise in millisecond | Remark                  |
| <b>Main Enclosure</b>                 |          |                |                      |                                      |                         |
| PPM/721201                            | Body     | Body           | 4.61                 | 15.24                                | No evidence of distress |
| PPM/721202                            | Body     | Body           | 3.52                 | 24.9                                 | -do-                    |
| PPM/721203                            | Body     | Body           | 3.37                 | 25.92                                | -do-                    |
| <b>Terminal Enclosure</b>             |          |                |                      |                                      |                         |
| PPM/721204                            | Body     | Body           | 4.81                 | 6.66                                 | No evidence of distress |
| PPM/721205                            | Body     | Body           | 3.95                 | 6.84                                 | -do-                    |
| PPM/721206                            | Body     | Body           | 3.98                 | 7.02                                 | -do-                    |

\*Results shown for the pressure time curve (enclosed) are the highest recorded value obtained in the test.

**Result #B2: Overpressure Test (Static Method):** Hydraulic pressure test is conducted as per Cl. 15.1.3.1 of IS/IEC 60079-1: 2007.

| Enclosure          | Test reference nos. | Over pressure (kg/cm <sup>2</sup> ) maintained for 1 min. | Remark                   |
|--------------------|---------------------|---|--------------------------|
| Main Enclosure     | OPM/721207          | 8.0 kg/cm <sup>2</sup>                                    | No damage or deformation |
| Terminal Enclosure | OPM/721208          | 8.0 kg/cm <sup>2</sup>                                    | No damage or deformation |

**Result #B3: Test for Erosion by flame:**

Gas Mixture: Tests with 8% Ethylene in air for Gas Gr. IIB

 No. of Tests: 50 nos. tests in the terminal Enclosure  
 (Test Ref.: ERF/721209 to ERF/7731158)

Test Condition: As per Clause 15.1.2.1 for DMC molded terminals studs

सीएसआईआर - केवईअसं परीक्षण प्रकोष्ठ  
CSIR - CIMFR TESTING CELL




ORIGINAL COPY



## TEST CERTIFICATE / परीक्षण प्रमाण पत्र

ID Number: 72/12 Code Number: FLP/242/11  
 Test Date : 02/02/2012  
 Manufacturer Details : M/S KAYSONS TECHNO EQUIPMENTS PVT . LTD .  
 Manufacturer Address : 1802/7 , GIDC ESTATE , V . U . NAGAR , DIST . ANAND , GUJARAT .  
 Model / Type : TYPE NO . : KFL - A  
 Category No . : NA  
 Gas : ETHYLENE  
 Gas Group : IIB  
 Equipment Details : FLP/WP FLOOD LIGHT FITTING  
 Enclosure Details : MAIN ENCLOSURE  
 Serial / Badge No . : NA  
 Peak Pressure : 4.61 Bar at 15.24 ms

Explosion Pressure vs Time Graph

*Anil Kumar*  
16.2.12  
(Testing Officer)

*[Signature]*  
16.2.12  
(Discipline Head)


सीएसआईआर - केखईअसं परीक्षण प्रकोष्ठ  
CSIR - CIMFR TESTING CELL

ORIGINAL COPY



## TEST CERTIFICATE / परीक्षण प्रमाण पत्र

ID Number: 72/12 Code Number: FLP/242/11  
 Test Date: 02/02/2012  
 Manufacturer Details: M/S KAYSONS TECHNO EQUIPMENTS PVT. LTD.  
 Manufacturer Address: 1802/7, GIDC ESTATE, V. U. NAGAR, DIST. ANAND, GUJARAT.  
 Model / Type: TYPE NO.: KFL - A  
 Category No.: NA  
 Gas: ETHYLENE  
 Gas Group: IIB  
 Equipment Details: FLP/WP FLOOD LIGHT FITTING  
 Enclosure Details: TERMINAL ENCLOSURE  
 Serial / Badge No.: NA  
 Peak Pressure: 4.81 Bar at 6.66 ms

Explosion Pressure vs Time Graph

*Amit Kumar*  
16/2/12  
(Testing Officer)

*Shayl*  
16/2/12  
(Discipline Head)

सीएसआईआर - केवर्डेअसं परीक्षण प्रकोष्ठ

CSIR - CIMFR TESTING CELL



ORIGINAL COPY



TEST CELL (F-01) प्रमाण पत्र

FORMAT NO. CIMFR: DOM. F-02: F-01:REV-01)

(Flame &amp; Explosion Laboratory)

ID NO.: 72/11

Code No.: FLP/242/11-1211

**Result #B4: Test for Non transmission of internal ignition:****Gas Mixture: Test with 37% Hydrogen in air for Gas Gr. IIB****No. of Tests: 5 nos. test with each enclosure.****Test Condition: Clause 15.2, Table 6 and 15.2.1.1 (No precompression required)**

| Name of Enclosure  | Test Ref. Nos.                 | Gas Group | Gas Mixture % in Air | No. of Test | Result |
|--------------------|--------------------------------|-----------|----------------------|-------------|--------|
| Main Enclosure     | EIT/721259<br>to<br>EIT/721263 | IIB       | 37 % Hydrogen        | Five        | Pass   |
| Terminal Enclosure | EIT/721264<br>to<br>EIT/721268 | IIB       | 37 % Hydrogen        | Five        | Pass   |

**CONCLUSION:** The **FLP & WP Flood Light Fitting**, in cast aluminium Alloy LM-6 construction designated by **Type No.: KFL-A**, meets the test requirements for flameproofness as per IS/IEC 60079-1:2007, general requirements as per IS/IEC 60079-0:2004 and weatherproof (IP-66 degree) as per IS/IEC 60529:2001. Hence, the above mentioned apparatus may be used in Gas Group: IIB and zone 1 & 2 atmospheres only.

Reported By

*Arvind Kumar*  
(ARVIND KUMAR)  
Group III (2)

Dated: 16th February, 2012  
Flame & Explosion Laboratory  
Central Institute of Mining & Fuel Research, (CSIR)  
(Erstwhile: Central Mining Research Institute)  
Barwa Road, DHANBAD - 826 015,  
(JHARKHAND) INDIA

Approved By

*A. K. Singh*  
(A. K. SINGH)  
Head of the Department